



UNITED STATES ENVIRONMENTAL PROTECTION AGENCY
REGION IX
75 Hawthorne Street
San Francisco, CA 94105-3901

Wednesday, July 08, 2015

Ivan Sydney, Business Manager
First Mesa Consolidated Villages
P.O. Box 260
Polacca, AZ 86042

REPORT OF VIOLATIONS OF THE SAFE DRINKING WATER ACT

Dear Mr. Sydney:

This letter is to notify you of violations of the Safe Drinking Water Act (SDWA) and what must be done to correct the violations for the public water system (PWS) shown below:

Polacca, PWS ID#0400106

The violations reported by EPA Region 9 to EPA HQ for the period ending on 3/31/2015 can be found on the attached table.

Public Notification Requirements

The public must be notified any time there is a violation of the SDWA. Depending on the severity of the violation, the type of Public Notice required will fall into one of three "tiers." The final column of the table labeled "Public Notice Tier" indicated the type of Public Notice required for the associated violation. If this PWS is required to distribute an annual Consumer Confidence Report, the Tier 3 notifications can be included in that report. Public Notice templates and handbook can be obtained by request from EPA or can be found at:

<http://water.epa.gov/lawsregs/rulesregs/sdwa/publicnotification/compliancehelp.cfm>

Failure to comply with the public notice requirement will result in further violations.

Tier 1 violations require notification within 24 hours.

Tier 2 violations allow 30 days for notification.

Tier 3 violations require annual notification.


Return to Compliance

EPA determines that the drinking water system has returned to compliance when the system reports the required sample results, or corrects the violation appropriately. An official Return to Compliance (RTC) will be entered into our records at that point. All violations and RTCs are reported to the EPA website, see: http://www.epa-echo.gov/echo/compliance_report_sdwa.html

Violations of the SDWA that are not corrected lead to a PWS being designated as an 'Enforcement Priority', as identified on EPA's national Enforcement Targeting Tool list. Drinking water systems that acquire this designation are targeted priorities for possible enforcement action by EPA. Furthermore, Enforcement Priority status precludes eligibility for funding under our infrastructure program, unless the proposed project will bring the system into compliance.

If your system has returned to compliance including the requirement to provide public notice, no further action is necessary. If you have questions regarding this matter, please contact Bessie Lee of my staff at (415) 972-3776.

Sincerely,

A handwritten signature in black ink, appearing to read 'D Albright', with a stylized flourish at the end.

David Albright, Manager
Drinking Water Protection Section

cc: Herman Honanie, Chairman
Alfonso Sakeva, Water Operator
Lionel Puhuyesva, Director, WRP
Sharon Grover, Administrative Assistant

Violation Type: Failure to post/submit official Public Notification as required by SDWA.

<u>Contaminant</u>	<u>Violation Period*</u>	<u>Sample Date</u>	<u>Result</u>	<u>Violation Comment +</u>	<u>Public Notice Tier</u>
Public Notice Rule	10/1/2014			Failure to post or submit Tier 2 Public Notice for Violation type: MCL, Average - EP002: Running annual average violation calculated from the last sample submitted and the group of results from the previous 4 quarters.: Arsenic: 10/1/2014	3

The Water System must do the following: Post and submit required Public Notice.

Violation Type: Major monitoring/reporting violation for routine chemical monitoring.

<u>Contaminant</u>	<u>Violation Period*</u>	<u>Sample Date</u>	<u>Result</u>	<u>Violation Comment +</u>	<u>Public Notice Tier</u>
Arsenic	1/1/2015 3/31/2015	N/A	N/A	Failed to monitor and/or report required monitoring results due quarterly.	3

The Water System must do the following: Report monitoring results as required.

Violation Type: Maximum Contaminant Level violation for chemical contaminant (running average, 4 qtrs.)

<u>Contaminant</u>	<u>Violation Period*</u>	<u>Sample Date</u>	<u>Result</u>	<u>Violation Comment +</u>	<u>Public Notice Tier</u>
Arsenic	1/1/2015 3/31/2015	N/A	.017	EP002: Running annual average violation calculated from the last sample submitted and the group of results from the previous 4 quarters.	2

The Water System must do the following: Report quarterly monitoring for contaminant in violation, until running annual average is below MCL for 6 months.

Violation Type: Minor monitoring/reporting violation for routine bacteriological monitoring.

<u>Contaminant</u>	<u>Violation Period*</u>	<u>Sample Date</u>	<u>Result</u>	<u>Violation Comment +</u>	<u>Public Notice Tier</u>
Total Coliform	1/1/2015 1/31/2015	N/A		2 reported results of the 3 samples required per month	3

The Water System must do the following: Report all future required results.

* Depending on the contaminant and your public water system's monitoring schedule, violations are reported in the quarter following the due date.

+ The comment field indicates the reason for the violation and may indicate whether the system has corrected the violation, issued public notice, or remains out of compliance.